

<b><u>Risk Assessment – Structural Demolition</u></b>							
<b>A. Hazard</b>	<b>B. Potential Risk What Goes Wrong</b>	<b>C. Risk Score</b>	<b>D. Risk Controls</b>	<b>E. Control Type</b>		<b>F. Res Risk Score</b>	<b>G. Person Responsible</b>
Structural instability due to age or deterioration	Death	20E	Engineer to inspect if required	Admin	2	18	PCBU. S.
			Licensed demolisher to inspect	Admin	2		S.
			Use machine to test integrity of structure	Admin	2		PCBU. S.
			Training of workers	Admin	2		PCBU. S.
			Site induction	Admin	2		PCBU. S.
			Exclusion zones	ISE	3		PCBU. S. W.
			Signage	ISE	3		PCBU. S. W.
			SWMS / Safety management Plan	Admin	2	ALARP	PCBU. S.
<b>A. Hazard</b>	<b>B. Potential Risk What Goes Wrong</b>	<b>C. Risk Score</b>	<b>D. Risk Controls</b>	<b>E. Control Type</b>		<b>F. Res Risk Score</b>	<b>G. Person Responsible</b>
Dust	Damage to Environment and workers	15E	SWMS / Permit to work	Admin	2	14	PCBU. S.
			Tool box talk	Admin	2		S.
			Supervision of workers	Admin	2		PCBU. S.
			Training of workers	Admin	2		PCBU. S.
			Site induction	Admin	2		PCBU. S.
			Water suppression	ISE	3		PCBU. S. W.
			Appropriate PPE	PPE	1		PCBU. S. W.
						ALARP	PCBU. S. W.

ALARP = As low as Reasonably Practicable. You must monitor worker compliance with the SWMS.



# WHIRLIGIG COMPLIANCE

A. Hazard	B. Potential Risk What Goes Wrong	C. Risk Score	D. Risk Controls	E. Control Type		F. Res Risk Score	G. Person Responsible	
Structural collapse	Death or property damage	20E	SWMS / Permit to work	Admin	2	18	PCBU. S.	
			Tool box talk	Admin	2		S.	
			Supervision of workers	Admin	2		PCBU. S.	
			Training of workers	Admin	2		PCBU. S.	
			Site induction	Admin	2		PCBU. S.	
			VOC for Plant operators	Admin	2		PCBU. S.	
			Exclusion zones	ISE	3		PCBU. S. W.	
			Signage	ISE	3		PCBU. S. W.	
								ALARP
A. Hazard	B. Potential Risk What Goes Wrong	C. Risk Score	D. Risk Controls	E. Control Type		F. Res Risk Score	G. Person Responsible	
Excessive waste to landfill	Damage to environment	16E	Sorting of waste	Admin	2	12	PCBU. S. W.	
			Recycling where possible	Admin	2		PCBU. S. W.	
			SWMS / Permit to work	Admin	2		PCBU. S.	
			Tool box talk	Admin	2		PCBU. S.	
			Supervision of workers	Admin	2		PCBU. S.	
			Training of workers	Admin	2		PCBU. S.	
								ALARP

ALARP = As low as Reasonably Practicable. You must monitor worker compliance with the SWMS.