

Risk Assessment – Heights - Ladders							
A. Hazard	B. Potential Risk What Goes Wrong	C. Risk Score	D. Risk Controls	E. Control Type		F. Res Risk Score	G. Person Responsible
Falls from Ladders	Death or serious bodily injury	20E	SWMS	Admin	2	19	PCBU. S.
			Tool box talk	Admin	2		PCBU. S. W.
			Supervision	Admin	2		PCBU. S.
			Work at heights training	Admin	2		PCBU. S. W.
			Maintain 3 points of contact	ISE	3		PCBU. S. W.
			Not to be used as a work platform	Admin	2		PCBU. S. W.
			Install handrails and braces to scaffold	ISE	3		PCBU. S.
			Ensure installed on level ground or use adjustable legs	ISE	3		ALARP
A. Hazard	B. Potential Risk What Goes Wrong	C. Risk Score	D. Risk Controls	E. Control Type		F. Res Risk Score	G. Person Responsible
Falling objects	Death or serious bodily injury	20E	SWMS	Admin	2	18	PCBU. S.
			Tool box talk	Admin	2		PCBU. S. W.
			Supervision	Admin	2		PCBU. S.
			Risk assessment / SWMS	Admin	2		PCBU. S. W.
			Exclusion zones	ISE	3		PCBU. S.
			Signage	ISE	3		PCBU. S.
			Hard hats for workers below	PPE	1		PCBU. S. W.
			Use lanyards or minimize storage on planks	ISE	3		ALARP

ALARP = As low as Reasonably Practicable. You must monitor worker compliance with the SWMS.