

Risk Assessment - Lifting equipment

A. Hazard	B. Potential Risk What Goes Wrong	C. Risk Score	D. Risk Controls	E. Control Type		F. Res Risk Score	G. Person Responsible
Use of Lifting equipment	Death or serious bodily injury	20E	SWMS	Admin	2	18	PCBU. S.
			Toolbox talk	Admin	2		PCBU. S. W.
			Supervision	Admin	2		PCBU. S.
			Risk assessment / SWMS	Admin	2		PCBU. S. W.
			Trained & competent workers	Admin	2		PCBU. S.
			Exclusion zones	ISE	3		PCBU. S.
			Signage	ISE	3		PCBU. S.
			VOC for plant operators	Admin	2		ALARP
A. Hazard	B. Potential Risk What Goes Wrong	C. Risk Score	D. Risk Controls	E. Control Type		F. Res Risk Score	G. Person Responsible
Oil leaks from Lifting equipment	Heat stroke / sunburn	15E	SWMS	Admin	2	13	PCBU. S.
			Toolbox talk	Admin	2		PCBU. S. W.
			Supervision	Admin	2		PCBU. S. W.
			Hat	PPE	1		PCBU. S. W.
			Sunscreen	PPE	1		PCBU. S. W.
			Take breaks	Admin	2		PCBU. S. W.
			Long sleeve shirts	PPE	1		PCBU. S. W.
			Hydration	Admin	2		ALARP

ALARP = As low as Reasonably Practicable. You must monitor worker compliance with the SWMS.

A. Hazard	B. Potential Risk What Goes Wrong	C. Risk Score	D. Risk Controls	E. Control Type		F. Res Risk Score	G. Person Responsibl e
Movement of Lifting equipment	Death or serious bodily injury	20E	SWMS	Admin	2	18	PCBU. S.
			Toolbox talk	Admin	2		PCBU. S. W.
			Supervision	Admin	2		PCBU. S.
			Risk assessment / SWMS	Admin	2		PCBU. S. W.
			Trained & competent workers	Admin	2		PCBU. S.
			Spotter	ISE	3		PCBU. S.
			Signage	ISE	3		PCBU. S.
			VOC for plant operators	Admin	2	ALARP	PCBU. S. W.
A. Hazard	B. Potential Risk What Goes Wrong	C. Risk Score	D. Risk Controls	E. Control Type		F. Res Risk Score	G. Person Responsibl e
Suspended loads	Death, crushing	25E	SWMS	Admin	2	19	PCBU. S.
			Toolbox talk	Admin	2		PCBU. S. W.
			Supervision	Admin	2		PCBU. S.
			Risk assessment / SWMS	Admin	2		PCBU. S. W.
			Trained & competent workers	Admin	2		PCBU. S.
			Spotter	ISE	3		PCBU. S.
			Signage	ISE	3		PCBU. S.
			Exclusion zones	ISE	3	ALARP	PCBU. S.

ALARP = As low as Reasonably Practicable. You must monitor worker compliance with the SWMS.